

SECTION 27 00 00 - COMMUNICATIONS BASIC REQUIREMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section specifies the common administration basic requirements and common methods for all low voltage systems installation work included under Division 27 and 28 and where those requirements differ from the requirements of this section, the more stringent shall govern.

1.02 STANDARDS, REGULATIONS, AND CODES REFERENCES

- A. The following Standards, Regulations and Codes apply to work specified in the Contract Documents.
1. Applicable State and Local Codes.
 2. California Building Code and California Electrical Code, Current Editions.
 3. BICSI TDMM (Telecommunications Distribution Methods Manual), 11th Edition 2006.
 4. ANSI/TIA/EIA-568-B.1. Commercial Building Telecommunications Cabling Standard,
 5. ANSI/TIA/EIA-568-B.1-2. Commercial Building Telecommunications Cabling Standard, Part 1: General Requirements, Addendum 2, Grounding and Bonding Specifications for Screened Balanced Twisted-Pair Horizontal Cabling.
 6. ANSI/TIA/EIA-568-B.1-3. Commercial Building Telecommunications Cabling Standard.
 7. ANSI/TIA/EIA-568-B.1-4. Commercial Building Telecommunications Cabling Standard, Part 1: General Requirements, Addendum 4, Recognition of Category 6 and Category Cat 6A and 50 nm Laser-Optimized 50/125 um Multimode Optical Fiber Cabling.
 8. ANSI/TIA/EIA-568-B.1-2. Commercial Building Telecommunications Cabling Standard, Part 2: Balanced Twisted-Pair Cabling Components.
 9. ANSI/TIA/EIA-568-B.2-1. Commercial Building Telecommunications Cabling Standard, Part 2: Balanced Twisted-Pair Cabling Components, Addendum 1, Transmission Performance Specifications for 4-Pair 100 Ohm Category 6 Cabling.
 10. ANSI/TIA/EIA-568-B.2-10 (draft 2.0). Commercial Building Telecommunications Cabling Standard, Part 2: Balanced Twisted-Pair Cabling Components, Addendum 10, Transmission Performance Specifications for 4-Pair 100 Ohm Augmented Category 6 Cabling.
 11. ANSI/TIA/EIA-568-B3.3 Optical Fiber Cabling Components Standard.
 12. TIA-569-B. Commercial Building Standard for Telecommunications Pathways and Spaces.
 13. ANSI/TIA/EIA-606-A. Administration Standard for Commercial Telecommunications Infrastructure.
 14. ANSI/TIA/EIA-607-A. Commercial Building Grounding (Earthing) and Bonding Requirements for Telecommunications.
 15. TIA/EIA TSB-67 Transmission Performance Specifications for Field Testing of Unshielded Twisted-Pair Cabling Systems.
 16. TIA/EIA TSB-72 Centralized Optical Fiber Cabling Guidelines.

1.03 DEFINITIONS

8. Cross-Connect: Equipment used to terminate and tie together communications circuits.
9. Cross-Connect Jumper: A cluster of twisted-pair conductors without connectors used to establish a circuit by linking two cross-connect termination points.
10. Fiber Optic Distribution Unit (FDU): Cabinet with terminating equipment used to develop fiber optic cross-connect facilities. Also known as LIU.
11. Grounding: a conducting connection to earth, or to some conducting body that serves in place of earth.
12. Hinged Cover Enclosure: Wall-mounted box with a hinged cover that is used to house and protect electrical devices.
13. Horizontal: Pathway facilities and media connecting communications rooms to Telecommunications Outlets.
14. Intermediate Distribution Frame (IDF): Data networking equipment rack and/or location that serves individual buildings. Downstream from MDF.
15. Jack: Receptacle used in conjunction with a plug to make electrical contact between communications circuits, e.g., eight-position/eight-contact modular jacks.

29. Wiring Block: Punch down terminating equipment used to develop twisted pair cross-connect facilities.

1.04 PRODUCT AVAILABILITY

A. Products with long lead times are to be brought to the attention of the project manager.

1.05 PRODUCT SUBMITTALS

A. See Division 01 Submittals for more requirements

1.06 SUBSTITUTION LIMITATIONS

A. Equivalent product(s) may be considered for substitution for those products specified, however, the equivalent product(s) must be approved, and show demonstrated and documented equivalence to the product(s) specified. Documentation includes but is not limited to product samples, data sheets, and actual test data. The request for product substitution, and supporting documentation, must be submitted, in writing.

B. See Division 01 Substitutions for more requirements

1.07 QUALITY ASSURANCE

A. Conform to requirements of the CEC, latest adopted version with amendments by local AHJs.

B. Conform to the latest adopted version of the CBC with amendments by local AHJs.

C. Obtain and pay for electrical permits, plan review, and inspections from local AHJs.

D. Furnish products listed by UL or other testing firm acceptable to AHJ.

E. Conform to requirements of the serving electric, telephone, and cable television utilities.

F. Contractor Qualifications:

1. Minimum of five years' experience in the design, installation, testing, and maintenance of low-voltage systems.
2. Maintain a local service facility which stocks spare devices and/or components for servicing systems.
3. Have performed successful installation and maintenance of at least three projects similar in scope and size. Be able to provide project references for these three projects, including scope of Work, project type, owner/user contact name and telephone number.
4. The contractor selected for this project must be certified by the manufacturer of the products and utilize these components for completion of work.

2. Show exact routes of cable tray, surface raceway, conduits, and service entrance conduits.
3. Show the exact location of racks, cabinets, mounting frames and the like.

3. Examine the entire set of Drawings to avoid conflicts with other systems. Determine exact route and installation of communications wiring and equipment with conditions of construction.

3.02 INSTALLATION

- A. Install communications equipment completely as directed by manufacturer's installation instructions. Obtain installation instructions from manufacturer prior to rough-in of the communications equipment, examine the instructions thoroughly. When requirements of the installation instructions conflict with the Contract Documents, request clarification from Project Manager/Designer prior to proceeding with the installation.
- B. Do not install communications equipment in obvious passages, doorways, scuttles, or crawl spaces which would impede or block the passage's intended usage.
- C. Do not install communications equipment in locations where it would obviously be subject to damage during normal usage.

3.03 FIELD QUALITY CONTROL

- A. Tests: Conduct tests of equipment and systems to demonstrate compliance with requirements specified in Division 27 & 28. Refer to individual Specification Sections for required tests. Document tests and include in Closeout Documents.

3.04 CLEANING

- A. Remove dirt and debris caused by the execution of the communications work.
- B. Leave the entire communications system installed under this Contract in a clean, dust-free, and proper working order.
- C. Vacuum clean interiors of new and modified electrical signal and communication equipment enclosures.

END OF SECTION

SECTION 27 05 00 - COMMON WORK RESULTS FOR COMMUNICATIONS

PART 1 - GENERAL

1.01 SUMMARY

- A. This section specifies the basic materials and methods for all low voltage pathways installation work included under Division 27 and 28 and where those requirements differ from the requirements of this section, the more stringent shall govern.
- B. This section adds refinements to Division 26 that apply to Communications and extra-low-voltage systems.

1.02 SCOPE

- A. Materials and/or methods for the following.
 - 1. Communication services
 - 2. Grounding
 - 3. Fasteners
 - 4. Hangers and supports
 - 5. Conduits/Backboxes/Raceways
 - 6. Underground
 - 7. Sleeves and penetrations

1.03 SUBMITTALS

- A. Submittals shall be done in accordance with District submittal procedures, see Division 01 Submittals for requirements.

1.04 RELATED REQUIREMENTS

- A. The General Conditions, Supplementary Conditions and Division 1 are fully applicable to this Section, as if repeated herein.
- B. 26 00 00 – Electrical
- C. 27 00 00 – Communications Basic Requirements

1.05 REFERENCES

- A. ANSI American Nation Standards Institute
- B. NFPA 70 – National Electrical Code

- C. UL Underwriters Laboratory
- D. California Building Code (CBC)
- E. California Electrical Code (CEC)

1.06 WARRANTY

- A. Refer to Division 01 -- Warranties

PART 2 – PRODUCTS

2.05 CONDUITS AND ACCESSORIES

A. CONDUITS

1. See Division 26 for requirements.
2. Conduit for Fire Alarm applications shall be red in color (non-accessible areas are excluded).
3. All new conduits shall be sized accordingly to achieve a 40% maximum fill ratio with initial cables installed.

B. INNERDUCT

1. Orange corrugated HDPE (High Density Polyethylene) Innerduct shall be used for fiber optic cable protection in interior locations.
2. Fabric multi-cell innerduct is approved for underground conduits 2" and larger.

C. FITTINGS:

1. See Division 26 for requirements.
2. Conduit bodies and any sharp bend fittings are strictly prohibited for communication Cat6A and fiber optic cables. Appropriate conduit sweeps are required.

D. PULL LINE

1. Minimum 1/8" diameter, or larger braided line of polypropylene or continuous fiber polyolefin. The minimum breaking strength of 1/8 in. line is 200 lbs.

2.06 BACKBOXES, JUNCTION BOXES AND FLOOR BOXES

- A. Galvanized one-piece or welded pressed steel type. Boxes for fixture shall not be less than 4" square and shall be equipped with fixture stud. Boxes shall be at least 2-1/8" deep, 4" square for 1 or 2 gang devices, with device rings. Boxes mounted in wall or ceiling finished with gypsum board shall be furnished with 5/8" deep device rings. Provide blank cover for all boxes without fixture or device.
- B. Junction boxes, larger than 8", located indoors shall be hinged, NEMA-1 rated.
- C. Junction boxes, larger than 8", located outdoors, or in wet or damp locations shall be hinged, NEMA-3R.
- D. Provide and install tamper-proof screws for all exterior boxes.

- E. Junction boxes used for Fire Alarm systems are to be red in color with red colored cover plates.

2.07 GROUND BOXES

- A. See Division 26 for requirements.
- B. Approved manufactures are Jensen, Christy or approved equal.
- C. All ground boxes shall have metal traffic-rated lids with permanent factory markings of COMM or COMMUNICATIONS.
- D. Minimum size is 17" x 30"

2.08 PENETRATION SEALING

- A. Firestopping: Provide UL Listed Firestopping materials for all penetrations through rated assemblies (walls / floors).

3.03 HANGERS AND SUPPORTS

- A. Install hangers and supports per manufacturer's written instructions.
- B. Hanger spacing shall be 48" or less and within 12" of sleeves and/or junction/back boxes.

3.04 LOW VOLTAGE PATHWAY/RACEWAYS

- A. EMT conduit may be used at following locations (see Division 26 for exact requirements):
 - 1. In dry locations in furred spaces.
 - 2. In partitions other than concrete or solid masonry.
 - 3. In protected exterior locations not exposed to direct weather.
- B. Rigid steel conduit and fittings shall be used for vertical risers and on top of all roofs, overhangs, walkways, canopies, or any other location exposed to direct weather. See Division 26 for exact requirements.
- C. Furnish and install pull lines in all unused (empty) conduits or raceways. All pull lines shall be permanently tagged with identification at both ends.
- D. Install exposed conduit neatly, parallel to or at right angles to structural members. Maintain a minimum of 12 inches of clearance from steam or hot water pipes. All installed strut channel supports should allow for future conduit attachments. The width of strut channel to match the width of the closest attached junction box. See design document details for attachment requirements.
- E. Supports: Support conduit with two-hole straps or strut channel where shown in design documents and/or specified. Coordinate supports with architectural details. Secure to wood structure by means of bolts or lag screws, to metal by means of shallow self-tapping screws, to concrete by means of insert or expansion bolts, to brickwork by means of expansion bolts, and to hollow masonry or stucco by means of toggle bolts.
- F. Spacing for all EMT and rigid steel conduit supports shall be as follows unless otherwise specified in design documents details:
 - 1. Surface conduit spacing and supports and unless otherwise specified or shown on drawing details:
 - a. EMT – Size 3/4" to 2" – 4' maximum spacing (3 each supports per 10' conduit length) and 12" from each end of conduit at coupling, connector or 90-degree bend.

- G. If conduit is designated for low voltage use, no more than a total of 360 degrees of conduit bend radius will be allowed between pull boxes.
- H. All junction boxes shall be connected to conduits using appropriate connecting hardware (i.e. box connectors).
- I. Clean, prep and paint with white primer all exposed conduit, junction boxes, channel strut, fittings, and accessories.
- J. Before pulling any conductors into an underground PVC conduit (new or existing), the conduit shall be first be proofed by pulling through a mandrel of a diameter $\frac{1}{4}$ in. smaller than the conduit inside dia., followed by a swab of the same diameter as the conduit inside diameter.
- K. Non-metallic raceway to be installed with mechanical fasteners only, do not remove adhesive tape backing.
- K. CAPPING
 - 1. Cap conduits during construction with manufactured seals. Swab out conduits before installing wires.
 - 2. Cap all empty conduits below grade and in pull boxes with manufacturer's caps to prevent entrance of debris, attach pull string to cap.

3.05 J-BOXES

- A. Screws shall be used to attach boxes, and must be accurately placed for finish, independently and securely supported by adequate wood backing or by manufactured adjustable channel type heavy-duty box hangers.

- A. Clean all work prior to concealing, painting, and acceptance. Performed in stages if directed.
- B. Clean and repair soiled or damaged painted exposed work and match adjoining work before final acceptance.
- C. Remove debris from inside and outside of equipment and enclosures.

3.09 FINAL DOCUMENT SUBMITTALS

- A. See 27 00 00 for more information.

END OF SECTION

SECTION 27 10 00 - STRUCTURED CABLING

PART 1 – GENERAL

1.01 SUMMARY

- A. This section specifies equipment, accessories, materials, installation, configuration, and testing requirements for a complete and operable Structured Cabling communications system. The system shall provide highly reliable and high-performance data communication from main distribution frame (MDF) through each intermediate distribution frame (IDF) to end points requiring fiber optics and/or copper cabling and associated equipment.
- B. This section condenses sections 27 11 00 – Communications Equipment Room Fittings, 27 13 00 – Communications Backbone Cabling, 27 15 00 – Communications Horizontal Cabling and 27 16 00 – Communications Connecting Cords into one comprehensive section.

1.02 SCOPE

- A. The work will include but not be limited to the following objectives:
 - 1. Contractor shall furnish and install all required components and accessories as outlined in the design documents for a complete and operable turn-key system.
 - 2. Quality workmanship is a high priority for the District and the Contractor shall be held to a high-level of professional workmanship. Contractors unfamiliar with the District's standards shall familiarize themselves with the standards and requirements prior to beginning work
 - 3. The Contractor shall furnish and install all required fire-treated $\frac{3}{4}$ " (three quarter inch) plywood for the MDF and all IDF locations.
 - 4. The Contractor shall furnish and install a ground bus bar at the MDF and IDF rooms.
 - 5. The Contractor shall furnish and install all required racks and cabinets.
 - 6. The Contractor shall furnish, install, and configure uninterruptable power supply(ies) (UPS) for the MDF and/or IDF racks.
 - 7. The Contractor shall furnish and install all newly required conduit/raceway.
 - 8. The Contractor shall furnish and install all wire/cable (copper/fiber optic) as required.
 - 9. The Contractor shall terminate all strands of fiber at each fiber enclosure.
 - 10. The Contractor shall furnish and install termination all end-point equipment (patch panels, jacks, wallplates, enclosures, etc.).
 - 11. The Contractor shall furnish and install all patch cords (copper/fiber).
 - 12. The Contractor shall test and certify installed cable plant.

1.03 RELATED REQUIREMENTS

Leaf Engineers
Project No. 230235

Camellia E.S. Tele-Center Upgrade Project
Sacramento City Unified School District

STRUCTURED CABLING
27 10 00

1.08 SUBMITTALS

A. See section 27 00 00 for requirements.

1.09 WARRANTY

A. Refer to Division 01 Warranty section.

B. See section 27 00 00 for additional requirements.

1. Contractor, prior to submitting a proposal, shall determine product availability and delivery time, and shall include such considerations into his proposed Contract Time.

2.02 MANUFACTURERS AND PRODUCTS

- A. See Appendix A at the end of this document for pre-approved materials.
- B. Substitutions require proof of equivalence and approval by District and/or its representative.

2.03 COPPER/FIBER OPTIC CABLES AND COMPONENTS

- A. All copper cables and components shall be Cat6A rated.
 1. Cable to be reduced diameter.
 2. Jacks to be keystone style.
- B. Patch cords system/color:
 1. Data = Blue color
 2. AP = Green color
 3. CCTV = Blue color
 4. Clock/Intercom = Yellow color
 5. Access Control = Black color
- C. Data jacks system/color:
 1. Data = White color
 2. AP = Green color
 3. CCTV = Blue color
 4. Clock/Intercom = Yellow color
 5. Access Control = Black color
- D. All fiber optic cables and components shall be single single-mode OS2 rated.
- E. Fiber optic cable terminations shall be FAAABB 0 10.4739r o6C-DBluee.

- C. The Contractor (or subcontractor listed at time of bid) must have at least five (5) years' experience before the Bid Opening Date.

3.02 EXAMINATION

- A. The Contractor shall be required to visit the installation site(s) prior to job bidding. The Contractor acknowledges that the failure to visit the site(s) will not relieve the Contractor of the responsibility for accurate bidding and performance of the Work.
- B. The Contractor shall report any discrepancies between the Specifications, Drawings, and Site Examination prior to the Bid Opening Date.

3.03 PREPARATION

- A. The Contractor shall order all required parts and equipment upon receipt of approved product submittals.
- B. The Contractor shall verify the availability of power where required.

3.04 SHOP DRAWINGS

- A. The Contractor shall create "Shop Drawings" per section 27 00 00 for this section.
- B. Submit drawings for review and approval by the Project Manager.

3.05 INSTALLATION

A. ENTRANCE FACILITIES

- 1. Contact telecommunications service provider and arrange for installation of demarcation point, protected entrance terminals, and housing when so directed by service provider.
- 2. Install underground or aerial pathways complying with recommendations in TIA/EIA-569-A, "Entrance Facilities" Article.

B. UNDERGROUND ENTRANCE PATHWAY

- 1. Install underground entrance pathway complying with Division 26.

C. EQUIPMENT RACKS, CABINETS, ENCLOSURES AND ACCESSORIES

- 1. Backboards:

- a. Shall be installed behind the rack or cabinet if the cabinet is not able to be directly attached to two vertical wall studs.
 - b. Backboards shall be made of fire retardant or treated materials, squarely cut, and with sanded edges
 - c. Backboards shall be a minimum ¾" thick and large enough to secure it to two vertical wall studs.
 - d. The "FIRE RATED" stamp shall be visible.
 - e. Backboards shall be fastened with ¼" lag bolt and washer, non-recessed, with maximum spacing of 18" into 2 vertical studs.
2. All data & voice communications racks and cabinets shall be anchored in accordance with manufacturer's specifications, project specifications and/or drawn details, to walls and floors and grounded to building ground grid (not to water pipes etc.).
 3. Securely mount equipment cabinet and racks to the building structure. A proper quantity of support fasteners shall be utilized. Typically lag bolts for wood installations, wedge anchors for concrete flooring. Submit data sheets for mounting fasteners for approval before installation. Mount equipment per DSA approved drawings/details.
 4. Equipment cabinet mounted on or against walls will have 3-foot clearance in front of deepest component and accessible to rear for service.
 5. MDF and all IDF's shall have at least one dedicated 120VAC quad-receptacle each.
 6. Patch Panels: Mount patch panels into the cabinet/rack. Match manufacturer of existing install or if new construction, see Appendix A.
 7. Cable Management: Secure the cable bundle(s) to the rack strain relief and cable management behind the patch panels and cross connect block panels. Install horizontal cable management panels and brackets for routing and management of patch cables. Maintain TIA/EIA and BICSI standards on bundling, supporting and bend radius.
 8. Surge Protected Outlet Strips: Required in MDF rack. Mount surge protected outlet strips per Manufacturer's directions. Refer to details on the Drawings for mounting location.
 9. Furnish and install UPS in bottom of MDF/IDF rack.
- D. MDF/IDF GROUNDING
1. Refer to Section 27 05 00 Grounding for more requirements.
 2. Locate grounding bus bar to minimize the length of bonding conductors. Fasten to wall allowing at least 2-inch (50-mm) clearance behind the grounding bus bar. Connect grounding bus bar

with a minimum No. 6 AWG grounding electrode conductor from grounding bus bar to suitable electrical building ground.

3. Bond metallic equipment (including ladder rack) to the grounding bus bar, using not smaller than No. 6 AWG equipment grounding conductor.

3.06 WORKMANSHIP

- A. Quality workmanship is a high priority for the District and the Contractor shall be held to a high-level of professional workmanship.
- B. The District' Project or Construction Manager will have the authority to reject Work which does not conform to the Drawings and Specifications.
- C. Comply with highest industry standards, except when specified requirements indicate more rigid standards or more precise workmanship.
- D. Perform Work with persons experienced and qualified to produce workmanship specified.
- E. Maintain quality control over suppliers and Subcontractors.

3.07 WIRE/CABLE (COPPER/FIBER OPTIC)

- A. Design, layout, size, and plan new cable runs as required.
- B. All wire and cable passing through metalwork shall be sleeved by an approved grommet or bushing.
- C. Conduit/raceway fill shall not exceed 40 percent of interior cross-sectional area.
- D. Neatly dress and tie (Velcro) all cabling.
- E. UTP cabling shall conform to a 6-foot separation requirement from the main power panel, transformers, switchgear and/or starter motors adjacent to the MDF, IDF and termination locations.
- F. Fiber optic cable shall be installed from the MDF to each IDF.
- G. Orange corrugated HDPE (High Density Polyethylene) Innerduct shall be used for fiber optic cable protection in all interior locations.
- H. Spicing of fiber optic cable shall be done with fusion splices.
- I. When required copper feeders (minimum 4-pair) are to be installed from the MDF to each IDF

Leaf Engineers
Project No. 230235

Camellia E.S. Tele-Center Upgrade Project
Sacramento City Unified School District

(White)		
Cat6A Data Jacks (White)	Ortronics	KT2J6A-88
Cat6A Data Jacks (Green)	Ortronics	KT2J6A-45
Cat6A Data Jacks (Blue)	Ortronics	KT2J6A-36
Cat6A Data Jacks (Yellow)	Ortronics	KT2J6A-44
Cat6A Data Jacks (Black)	Ortronics	KT2J6A-00
Cat6A Data Cable, Reduced Diameter, Riser (White = default)	Berk-Tek	11143100
Cat6A Data Cable, Reduced Diameter, Plenum (White = default)	Berk-Tek	11141651
Cat6A Data Cable, Reduced Diameter, Riser (Blue = CCTV/Access Control)	Berk-Tek	11142398
Cat6A Data Cable, Reduced Diameter, Plenum (Blue = CCTV/Access Control)	Berk-Tek	11141650
Cat6A Data Cable, Reduced Diameter, Indoor/Outdoor (Black)		
Cat6A Patch Cord (Blue)	Quiktron	576-A10-0xx (xx = length)
Cat6A Patch Cord (Green)	Quiktron	576-A20-0xx (xx = length)
Cat6 Patch Cord Slim 1' (Blue)	C2G	01072
Cat6 Patch Cord Slim 1' (Green)	C2G	01160
Fiber Optic LIU 1-RU	Ortronics, Infinium	INFC01U-M4-E
Fiber Optic LIU 2-RU	Ortronics, Infinium	INFC02U-M4-E
Fiber Optic Adapter	Ortronics, Infinium	HDFP-LCD12AC
Fiber Optic LC Field Term Connector	Ortronics	205KAN9GASM
Fiber Optic Fanout Kit	Ortronics	61500858
Fiber Optic Cable Single-Mode OS2, Indoor/Outdoor	Superior Essex	W4012J101
Fiber Optic Cable Single-	Berk-Tek	PDP012AB0707-I/O-C4(YEL)

Mode OS2, Indoor/Outdoor		

END OF SECTION

SECTION 27 21 00 - DATA COMMUNICATIONS NETWORK EQUIPMENT

PART I - GENERAL

1.01 SUMMARY

- A. This section specifies equipment, accessories, materials, installation, configuration, and testing requirements for a complete and operable data network system. The system shall provide reliable and high-performance data communication throughout the site.

1.02 SCOPE

- A. The work will include but not be limited to the following objectives:
 - 1. Provide, coordinate, and install all required equipment and accessories as outlined in the design documents for a complete and operable system.
 - 2. Labor and Materials: The Contractor shall provide and pay for all labor, supervision, materials, accessories, components, equipment, tools, utilities, construction equipment and machineTJ EUNICATIONS NETWORK EQUIPMEN40 44sp1(l ret(d testin)he fo)-1eTJ testi(:)1(on,fo)-1e(

- A. Contractor shall be located within 50 miles or less from the project site to support 2-hour response time.
- B. Five years' experience installing data network equipment and systems.

1.05 SYSTEM REQUIREMENTS

- A. Any new installations or existing system modifications shall seamlessly integrate into the site's existing data network infrastructure.

1.06 CONTRACTOR "SHOP DRAWINGS" DESIGN REQUIREMENTS

- A. See section 27 00 00 for requirements.

1.07 SUBMITTALS

- A. See section 27 00 00 for requirements.

1.08 WARRANTY

- A. Refer to Division 01 Warranty section.
- B. See section 27 00 00 for additional requirements.

1.09 CLOSEOUT DOCUMENTS

- A. See section 27 00 00 for requirements.

[
PART 2 - PRODUCTS

2.01 GENERAL

1. Contractor, prior to submitting a proposal, shall determine product availability and delivery time, and shall include such considerations into his proposed Contract Time.

Cisco

- B. The Contractor shall order all required parts and equipment only after receipt of approved product submittals from the Project Manager.
- C. The Contractor shall coordinate with the District's Technology Services department for needed IP addresses at least 2 weeks prior to configuration/installation.

3.04 SHOP DRAWINGS

- A. The Contractor shall create "Shop Drawings" per section 27 00 00.

3.05 WORKMANSHIP

- A. Quality workmanship is a high priority for the District and the Contractor shall be held to a high-level of professional workmanship.
- B. The District's Project or Construction Manager will have the authority to reject Work which does not conform to the Drawings and Specifications.
- C. Comply with highest industry standards, except when specified requirements indicate more rigid standards or more precise workmanship.
- D. Perform Work with persons experienced and qualified to produce workmanship specified.
- E. Maintain quality control over suppliers and Subcontractors.

3.06 PATHWAY AND EQUIPMENT INSTALLATION

- A. Install all conduit and pathway per design documents. Refer to 27 05 00 for additional information/requirements.
- B. Install all Cat6A cable per design documents. Refer to 27 15 00 for additional information/requirements.
- C. Equipment to be installed per manufacturer's instructions.
- D. Devices requiring PoE power shall be connected to a PoE switch in the MDF/IDF data rack – verify with Technology Services for available PoE power.

3.07 CONFIGURATION

- A. Any information needed from the District for configuration of equipment (i.e. VLAN, etc.) needs to be requested in writing 2 weeks prior.

- B. All equipment to be fully configured and tested for functionality by the Contractor prior to District acceptance testing.

3.08 FIELD QUALITY CONTROL AND TESTING

- A. Upon reaching substantial completion, perform a complete test and inspection of the system. If found to be installed and operating properly, notify the District of readiness to perform the formal Test & Inspection of the complete system by the District or its representative. Make all adjustments/changes required from District/representative review.
- B. Submit the Record Drawings (as-builts) to District for review prior to inspection.
- C. During the formal Test & Inspection (Commissioning) of the system and have personnel available with tools and equipment to inspect wiring, devices, and system operation.
- D. If corrections are needed, the Contractor will be provided with a Punch-List of all discrepancies. Perform the needed corrections in a timely fashion.
- E. Notify the District when ready to perform a re-inspection of the installation.

3.10 AS-BUILT DRAWINGS

- A. See section 27 00 00 for requirements.

[

Equipment Appendix - Provide the following network and UPS equipment for Camellia Elementary as shown below:

QUANTITY	DESCRIPTION	MANUFACTURER
4	C9300I, DNA E, 24 3Y	Cisco - C9300I, DNA Essentials, 24 Port, 3 year term

- I. Existing systems shall remain operable until the new system is accepted and approved by the District or the District's representative.
- J. The Contractor is responsible for user/operator training (maximum 2 hours).
- K. The Contractor shall complete all required project closeout documentation in a timely fashion.

1.03 RELATED REQUIREMENTS

- A. The General Conditions, Supplementary Conditions and Division 1 are fully applicable to this Section, as if repeated herein.
- B. Section 27 00 00 - Communications
- C. Section 27 05 00 – Common Work Results for Communication Systems.

- B. Contractor shall be located within 50 miles or less from the project site to support 2-hour response time.
- B. Five (5) years' experience installing Rauland Telecenter equipment.
- C. The contractor shall possess a California a C7 or C10 license.
- D. The Contractor or Subcontractor shall be Rauland Telecenter authorized to provide and install equipment with 5 years documented experience.

1.10 CERTIFICATIONS

- A. Installers shall be manufacturer certified..

1.11 WORKMANSHIP

- A. Quality workmanship is a high priority for the District and the Contractor shall be held to a high-level of professional workmanship.
- B. The District's Project or Construction Manager will have the authority to reject Work which does not conform to the Drawings and Specifications.
- C. Comply with highest industry standards, except when specified requirements indicate more rigid standards or more precise workmanship.
- D. Perform Work with persons experienced and qualified to produce workmanship specified.

- A. The equipment shall only be installed by Contractors who are qualified and certified by the manufacturer to install and maintain the system.
- B. The Contractor (or subcontractor listed at time of bid) must have at least five (5) years' experience installing educational intercom equipment before the Bid Opening Date.

3.02 EXAMINATION

- A. The Contractor shall be required to visit the installation site(s) prior to bidding the job. The Contractor acknowledges that the failure to visit the site(s) will not relieve the Contractor of the responsibility for observing and considering those conditions which a Contractor would have observed and considered during a site visit, estimating properly the difficulty and cost of successfully performing the Work or proceeding to perform the Work without additional cost to District.
- B. The Contractor shall report any discrepancies in the Specifications, Drawings, and site information prior to the Bid Opening Date.

3.32 T

Leaf Engineers
Project No. 230235

Camellia E.S. Tele-Center Upgrade Project
Sacramento City Unified School District

- E. Notify the District when ready to perform a re-inspection of the installation.
- F. District or its representative to provide final sign-off for acceptance.

3.11 AS-BUILT DRAWINGS

- A. See section 27 00 00 for requirements.
- B. As-built riser diagram showing all access control components for site.

3.12 TRAINING

- A. For new systems provide 8-hrs end-user training.
- B. For existing system upgrades provide 2-hrs end-user training.

APPENDIX A – Pre-Approved Materials

DESCRIPTION	MFG	PART NUMBER
IP Campus Controller and software/lic(e/li 0 1 36 101.4369		

Clock/Speaker surface combo (for use with 12" Round clocks)	Rauland	- Baffle ACC3011S - Message Board TCC3011S Add: IP Classroom module Speaker: ACC1480 (USO880 w/ RJ-45) Add: IP Classroom module
	Lowell Lowell	Surface backbox: PC712 Baffle: AP-700
Exterior Speaker Enclosure (for use with all exterior speakers and paging horns)	Rauland	Backbox: ACC1113 Baffle: ACC1012

- D. Perform Work with persons experienced and qualified to produce workmanship specified.
- E. Maintain quality control over suppliers and Subcontractors.
- F. Contractor shall be responsible for scheduling Subcontractors in a timely fashion.

1.12 WARRANTY

- A. Refer to Division 01 Warranty section.
- B. See section 27 00 00 for additional requirements.

1.13 CLOSEOUT DOCUMENTS

- A. See section 27 00 00 for requirements.

PART 2 - PRODUCTS

2.01 GENERAL

- A. Manufacturers - See Appendix A at the end of this document for pre-approved materials.
- B. All products shall be new, unused and without blemishes and shall be of manufacturer's current and standard production.
- C. Drawings and Specifications indicate major system components, and may not show every component, connector, module, or accessory that may be required to support the operation specified. The Contractor shall provide all components needed for complete and satisfactory installation and operation.
- D. Product Availability
 - 1. The Contractor, prior to submitting a proposal, shall determine product availability and delivery time, and shall include such considerations into his proposed Contract Time.
 - 2. Subject to compliance with these specifications, products and systems included in this section are to be installed as specified by the manufacturer of the system or engineer approved equal.

2.02 EQUIPMENT

- A. See Appendix A at the end of this document for pre-approved materials.
- B. Substitutions require proof of equivalence and prior approval by District and/or its representative before ordering.

PART 3 - EXECUTION

3.01 ACCEPTABLE INSTALLERS

- A. The equipment shall only be installed by Contractors who are qualified to install and maintain the system.
- B. The Contractor (or subcontractor listed at time of bid) must have at least five (5) years' experience installing electronic clock equipment before the Bid Opening Date.

3.02 EXAMINATION

- A. The Contractor shall be required to visit the installation site(s) prior to bidding the job. The Contractor acknowledges that the failure to visit the site(s) will not relieve the Contractor of the responsibility for observing and considering those conditions which a Contractor would have observed and considered during a site visit, estimating properly the difficulty and cost of successfully performing the Work or proceeding to perform the Work without additional cost to District.
- B. The Contractor shall report any discrepancies between the Specifications, Drawings, and Site Examination prior to the Bid Opening Date.

3.03 PREPARATION

- A. The Contractor shall verify materials are readily available prior to submitting product submittals and notify the District's Project Manager of long lead time items.
- B. The Contractor shall order all required parts and equipment only after receipt of approved product submittals from the District's Project Manager.
- C. Submit and receive approval for shop drawings prior to work commencement.

3.04 PATHWAY INSTALLATION

- A. See Division 26 and Section 27 05 00 for requirements and more information.
- B. Existing Construction:
 - 1. Refer to design documents.

3.05 EQUIPMENT INSTALLATION

- A. Equipment to be wired and installed per manufacturer's instructions.

3.11 AS-BUILT DRAWINGS

A. See section 27 00 00 for requirements.

APPENDIX A – Pre-Approved Materials

DESCRIPTION	MFG	PART NUMBER
Clock (IP Sweep)	Sapling	SAP-1BS-xxR-0 (xx=09/9", 12/12", 16/16")
Clock (IP Digital)	Sapling	SBP-31S-254-0W
Protective Cage	National Time or STI	
Digital Messaging Board, Small	Rauland	TCC3011S
Digital Messaging Board, Large	Rauland	TCC3012L

]

END OF APPENDIX
END OF SECTION