



ADDENDUM NO. 2.0

Date: 07/17/2023

Issued by: Sacramento City Unified School District

**Project: Project #: 0520-464
Hiram Johnson HS Telecenter Upgrade Project**

This addendum shall supersede the original Information, attachments, and specifications regarding Project No. **0520-464** where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD 2.10:

Question: Is the District willing to consider amending the plans and specifications with an

Answer: No, Contractor is able to purchase equipment listed.

Message obtained from CDWG regarding this:

Project No: 0520-464
Hiram Johnson HS Telecenter Upgrade Project
ADDENDUM NO. 2

Project No: 0520-464
Hiram Johnson HS Telecenter Upgrade Project
ADDENDUM NO. 2

Answer:

The contractor should clip the wire where loose from the wall and leave it attached to the wall where the mural is.

AD 2.14:

Question: All exposed conduit observed on the jobwalk was EMT. Please confirm the conduit type requirements for all areas.

Answer: Typically we match whatever surface runway is available. If it's EMT then stay with that.

AD 2.15:

Question: The Iran Contra form is mentioned in bid documents but there is no form. Can you please supply?

Answer: This project does not have Iran Contracting Act certification requirements.

AD 2.16: Refer to DOCUMENT 00 11 16 **NOTICE TO BIDDERS**

REVISE **#6. /Notice To Bidders** as follows:

6. Electronic Bids will be received until 2:00 pm on July 20, 2023, after which time the bids will be opened and posted on eBuilder and SCUSD website.

END OF ADDENDUM NO. 2.0

Acknowledgement of this Addendum will be required at time of bid.