



Business Services

Contracts Office

5735 47th Avenue Sacramento, CA 95824

(916) 643-2464

John Quinto, Chief Business Officer

Jessica Sulli, Contract Specialist

ADDENDUM NO. 2

Date: January 11, 2019

Issued by: Sacramento City Unified School District

Project: 0530-429, Luther Burbank CTEIG Renovation

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

-
1. Provide an allowance in the Bid of \$15,000.00 for the complete and proper removal, backfill, and capping of the existing below floor lift ram defined on drawing A2.01. A revised _____ has been provided.
 2. Include in the Bid, the existing storage container, at the southwest corner of the building exterior, will need to be relocated during construction to facilitate the work in the area defined and reinstalled after the work is complete.
 3. Include in the Bid, the abatement of the suspected hazardous pipe insulation defined on drawing A2.01 within the demoed wall and on the suspended pipe overhead.

the wall/soffit and cap accordingly behind finishes.
 4. Include in Bid, the removal and capping of two (2) existing irrigation quick connects, along the north edge of the north walk, defined as HB Box on drawing CO.1.

END OF ADDENDUM NO. 2

BID FORM AND PROPOSAL

ACKNOWLEDGEMENT OF GENERAL CONDITIONS

Alternate #1

CONCRETE PAD AND RAILING PER SHEETS A2.01 AND A2.02

BID SUBMISSION

